2601/201 2602/201 2603/201 CONTROL SYSTEMS AND PROGRAMMABLE LOGIC CONTROLLERS June/ July 2019 Time: 3 hours



THE KENYA NATIONAL EXAMINATIONS COUNCIL

DIPLOMA IN ELECTRICAL AND ELECTRONIC ENGINEERING (POWER OPTION) (TELECOMMUNICATION OPTION) (INSTRUMENTATION OPTION) MODULE II

CONTROL SYSTEMS AND PROGRAMMABLE LOGIC CONTROLLERS

3 hours

INSTRUCTIONS TO CANDIDATES

You should have the following for this examination:

Answer booklet:

Mathematical tables Non-programmable Scientific calculator;

Drawing instruments;

Table of Laplace Transforms.

This paper consists of EIGHT questions in TWO sections; A and B.

Answer THREE questions from section A and TWO questions from section B in the answer booklet provided.

All questions carry equal marks.

Maximum marks for each part of a question are as indicated.

Candidates should answer the questions in English.

This paper consists of 9 printed pages.

Candidates should check the question paper to ascertain that all the pages are printed as indicated and that no questions are missing.

SECTION A: CONTROL SYSTEMS


Answer THREE questions from this section.

- For each of the following control systems, state with a reason whether it is open 1. (a) or closed loop:
 - (i) a bread toaster;
 - a man walking on a road; (ii)
 - a photocell-controlled street lighting system. (iii)

(6 marks)

- State the three types of forces that exist in translational control systems. (i) (b)
 - (ii) Figure 1 shows a mass spring system.
 - Derive the system equation if at equilibrium condition M = 15 kg. (I) B = 40 N/M/sec and K = 10 N/M.
 - Derive the transfer function using Laplace transforms. (H)


(9 marks)



- Fig.1
- With aid of a sketch, define an impulse function. (c) (i)
 - Determine the transfer function of a system whose time response is $f(t) = e^{-x}$. (ii) (5 marks)
- State two reasons why mechanical system are usually studied using electrical 2. (i) (a) analogy.

(ii) Figure 2 shows a circuit diagram of an Op-amp based electrical network.

Assuming the Op-amp is ideal, determine its transfer function, $V_{a(a)}/V_{a(a)}$



(8 marks)

- (b) A control system has poles at $S_1 = -1$ and $S_2 = -2 \pm j$, zeros at $S_3 = -3 \pm j$. If the gain factor is 5:
 - (i) Draw the pole-zero plot;
 - (ii) Write down the transfer function of the system;
 - (iii) State with a reason whether the system is stable or not.

(6 marks)


(c) A feedback control system has a characteristic equation given by:

$$S(S^2 + S + 1)(S + 4) + K = 0$$

Using the Routh-Hurwitz stability analysis method, determine the range of K for the system to remain stable.

(6 marks)

- 3. (a) (i) State two properties of signal flow graphs.
 - (ii) Figure 3 shows a signal flow graph of a control system. Obtain its transfer function.



(10 marks)

(b) Figure 4 shows a liquid level control system. Take:

q = inflow rate of the liquid in m³/sec

q = outflow rate of the liquid in m3/sec

h = height of the liquid in m

R = resistance of the outlet pipe

C = capacitance of the tank

Derive the expression for:

- outflow, q (i)
- (ii) rate of storage;
- overall transfer function of the system. (iii)

(6 marks)




Fig. 4

- (c) Explain the importance of each of the following with respect to analog computing:
 - (i) time scaling;
 - (ii) amplitude scaling.

(4 marks)

- 4) (a) State:
 - (i) two types of stepper motors;
 - (ii) two advantages of D.C tachometers.

(4 marks)

(b) A servomeechanism is represented by the equation:

$$\frac{d^2\theta}{dt^2} + 10\frac{d\theta}{dt} = 150 E$$

Where $E = (r - \theta)$ is the actuating signal.

Determine the:

- (i) transfer function;
- (ii) undamped frequency of oscillations;
- (iii) damping ratio;
- (iv) damped frequency of oscillations.

(9 marks)

- (c) (i) Define steady-state error.
 - (ii) The open loop transfer function of a control system is given by:

$$G(s) = \frac{4}{s+1}$$

- (I) State with reasons whether the system is a type 0, 1 or 2.
- (II) Determine steady-state error when a unit step input is applied.

(7 marks)

- (5) (a) (i) State the Nyquist stability criterion.
 - (ii) A system's open-loop transfer function is given by:


$$G_{(s)} H_{(s)} = \frac{1}{s(1+2s)(1+s)}$$

- (I) Show that the phase cross over frequency, $w = \frac{1}{\sqrt{2}}$ rad/sec.
- (II) Determine the phase cross over magnitude.
- (iii) Comment on the stability of the system in a (ii).

(12 marks)

2601/201 2602/201 2603/201 (b) Figure 5 shows an asymptotic Bode plot of a control system. Determine its transfer function.

(8 marks)



SECTION B: PROGRAMMABLE LOGIC CONTROLLERS

Answer TWO questions from this section.


- (a) Describe each of the following sensors as used in programmable logic controllers (PLC):
 - (i) optical;
 - (ii) ultrasonic.

(4 marks)

- (b) (i) A motor, M is controlled to run in forward and reverse directions by two buttons F and R respectively. The motor should not run when both buttons are pressed.
 - Draw the ladder diagram for this control;
 - (II) Write the equivalent instruction list program for the ladder diagram.

(ii) Figure 6 shows a ladder diagram of a control system. Describe the system operation.

(13 marks)



- Fig. 6
- (c) Define each of the following with respect to PLC memory:
 - (i) Address;
 - (ii) Random access;
 - (iii) Solid State Drive (SSD).

(3 marks)

- 7. (a) (i) Define a SCADA system stating two potential areas of application.
 - (ii) Describe each of the following SCADA system communication media:
 - (I) coaxial cable; -
 - (II) satellite;
 - (III) fibre optic cable.

(9 marks)



(b) (i) SCADA software can be compromised either internally or externally. List four risks that the system could suffer after such attacks. Draw a labelled diagram illustrating a SCADA network "ring of defences" (ii) (9 marks) State two organisations involved in the standardization of SCADA systems. (c) (2 marks) Define a calibration software. 8. (a) (1) Explain three merits of using calibration software. (ii) (7 marks) With the aid of labelled diagrams, describe each of the following Highway Addressable (b) Remote Transducer (HART) communication modes: (i) point-to-point; (ii) mutli-drop. (8 marks) State: (c) (i) two functions of Network Adaptor Cards (NAC) in data networks; three parameters that two NACs must agree on to communicate. (ii) (5 marks)

TABLE OF LAPLACE TRANSFORMS

| | FUNCTION F(t) | TRANSFORM ∫₀ e F(t) dt |
|-----|----------------------------------|------------------------------------|
| 1. | 1 | 1/s |
| 2. | e* | 1/(s - a) |
| 3. | sin at | $a/(s^2 + a^2)$ |
| 4. | cos at | $s/(s^2+a^2)$ |
| 5. | t | 1/s² |
| 6. | t ⁿ (n a +ve integer) | n!/s ⁿ⁺¹ |
| 7. | sinh at | $a/(s^2 - a^2)$ |
| 8. | cosh at | s/s ² -a ²) |
| 9. | t sin at | $2as/(s^2 + a^2)^2$ |
| 10. | t cos at | $(s^2 - a^2)/(s^2 + a^2)^2$ |
| 11. | e-str | n!/(s + a) ⁿ⁺¹ |
| 12. | e ⁻ cos ωt | $(s+a)/[(s+a)^2+\omega^2]$ |
| 13. | e ^{-st} sin ωt | $\omega/[(s+a)^2+\omega^2]$ |
| 14. | e cosh ωt | $(s+a)/[(s+a)^2-\omega^2]$ |
| 15. | e [™] sinhωt | $\omega/[(s+a)^2-\omega^2]$ |

Some Theorems used in Laplace Transforms.

- 1. If f(s) = L(F(t)), then $f(s + a) = L(e^{-a} F(t))$
- 2. $L\{dx/dt\} = sL\{x\} x(0)$ (b) $L\{d^2x/dt^2\} = s^2L\{x\} sx(0) x'(0)$

THIS IS THE LAST PRINTED PAGE.